

Hayk Faramazyan
General Director
GNC-ALFA Closed Joint-Stock Company
1 Khaghaghutyan Street
Abovyan, Kotayk 2201
Republic of Armenia



29 April 2025

Tier III Certification of Design Documents for GNC-ALFA CJSC – Data Center “Abovyan” in Abovyan, Republic of Armenia

Dear Hayk Faramazyan,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Design Documents for the GNC-ALFA Closed Joint-Stock Company (CJSC) – Data Center “Abovyan” as fulfilling Tier III Concurrently Maintainable criteria. This Certification is based upon the design documentation submitted between 17 January 2024 and 7 March 2025.

This Certification recognizes that GNC-ALFA CJSC – Data Center “Abovyan” is capable of supporting any planned work on the site infrastructure without disrupting operations more than the redundant computer room power and cooling capacity. This Tier III Certification is limited by the stated total peak IT load of 1,016 kilowatts (kW). This includes 510 kW in Machine Hall 1 (Room 101) and 506 kW in Machine Hall 2 (Room 102).

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operator errors, such as procedural errors during reconfiguration of the redundant computer room or site infrastructure equipment, may also impact the critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

The Tier III Certification of Design Documents award is valid until 29 April 2027, subject to the limitations and extension request process set forth in the attached Schedule I.

Congratulations on this achievement.

Sincerely,



Christopher Brown
Chief Technical Officer